



**Gregory N. O'Quinn**  
**Bureau of Regional and Laboratory Services**  
206 Beaufort St. NE  
Aiken, SC 29801

ENVIRONMENTAL COMPLIANCE &

October 13, 2025

OCT 22 2025

Mr. Matthew Baker, Acting SRS Remedial Project Manager  
Remediation and Deactivation & Decommissioning Division  
U. S. Department of Energy  
Savannah River Operations Office  
Post Office Box A  
Aiken, South Carolina 29802

AREA COMPLETION PROJECTS

Re: Decommissioning Project Final Report 607-3F, Sanitary Lift Station (V-PCOR-F-00097, Revision 0, July 30, 2025) received August 14, 2025.

Dear Mr. Baker:

The South Carolina Department of Environmental Services (SCDES) has reviewed the above referenced document with respect to the Memorandum of Agreement for Achieving an Accelerated Cleanup Vision for the Savannah River Site. As a result of this review, the Department has generated the attached comments. These comments must be addressed prior to final approval of the above referenced document. The appropriate technical staff will be available to participate in a joint DOE/EPA/SCDES comment resolution meeting to discuss this comment, if necessary.

To schedule a meeting to resolve these comments or to obtain further information, please contact me at (803) 508-7615.

Sincerely,

A handwritten signature in blue ink that reads "Gregory N. O'Quinn".

**Gregory N. O'Quinn, Director**  
Federal Facilities Agreement  
Bureau of Regional and Laboratory Services  
Aiken/Orangeburg

cc: C. L. Bergren, SRNS-ACP (Signed Original)  
Jon Richards, EPA Region IV  
Susan Fulmer, SCDES Bureau of Land and Waste Management, Federal  
Remediation Section

**South Carolina Department of Environmental Services Comments on:**  
Decommissioning Project Final Report 607-3F, Sanitary Lift Station (V-PCOR-F-00097, Revision 0, July 30, 2025) received August 14, 2025.

Page 1 of 1

**General Comment**

1. The referenced building in the title of this Decommissioning Project Final Report is identified as the 607-3F Sanitary Lift Station and is referenced as this in the cover letter, the signature page of the document, and in latter sections of the document. However, the building is referenced as the 607-3F Sewage Lift Station in the Facility Decommissioning Evaluation (FDE) from 2023 as well as the initial sections of this DPFR. Additionally, within the References section, Reference 8.1 refers to the building as the Sanitary Lift Station while References 8.7, 8.8, and 8.9 refer to the building as the Sewage Lift Station. Appendix K.1 of the FFA lists this building as the 607-3F Sewage Lift Station. For consistency and clarity related to previous and future documents and references regarding this building, please revise the document to reflect the building name as shown in Appendix K.1 of the FFA as well as the FDE pertaining to this building.

**Specific Comments**

2. Section 2.1, Facility Description, page 7. Sentence 2 of Paragraph 2 states "The building is constructed of galvanized steel with a minimum thickness of 24 gage for the walls...". Page 4 in the Facility Description/Discussion section of the Facility Decommissioning Evaluation (FDE) for Building 607-3F Sewage Lift Station (G-FDE-F-00064) states a minimum thickness of 26 gage for the walls. Please clarify this discrepancy and revise this section of the document accordingly.
3. Section 2.1, Facility Description, page 7. Sentence 1 of Paragraph 3 states that the pump motor, fusible disconnect control panel and main disconnect for the sewage lift station are all located in the southwest corner. Page six of the FDE indicates that this equipment is located in the southeast corner. Please clarify this discrepancy and revise this section of the document accordingly.