

ENVIRONMENTAL COMPLIANCE & AREA COMPLETION PROJECTS

Baseline Asbestos Inspection Report of Building SRS-PB-EX0033





Savannah River
Nuclear Solutions, LLC
A Fluor Daniel Partnership

INTEROFFICE MEMORANDUM

Q-APG-D-00043
RSM Track Number 10755

February 25, 2021

TO: Kelsey Holcomb, 730-4B

FROM: Heath McGregor, 730-4B


BASELINE ASBESTOS INSPECTION REPORT OF BUILDING SRS-PB-EX0033


On February 22, 2021, an inspection was performed to determine the presence of any suspect Asbestos Containing Material (ACM) in building SRS-PB-EX0033. The 12' x 16' building (unknown date of construction) is comprised of prefabricated panels (metal/faux wood paneling, plastic, and polyisocyanurate insulation) and a metal roof. The structure is supported by a concrete slab foundation. The building is wired for electricity but was not connected to a power source at the time of this inspection. SRS-PB-EX0033 was formerly used as an office building, ancillary to the Coal Crusher House in D-Area.

SUMMARY

No visible, suspect ACM was discovered at the time of this inspection. Polyisocyanurate was the only Thermal System Insulation (TSI) identified during this inspection. Polyisocyanurate products do not contain asbestos. No suspect material was identified during the evaluation of the electrical wiring and electrical system components. This evaluation was based on visual inspection, tactile inspection and material knowledge.

In accordance with 40 CFR part 61-145 a **ten-day notification** must be filed with the South Carolina Department of Health and Environmental Control (SCDHEC) to obtain a demolition license, regardless of asbestos content. This is in concurrence with Lance Cramer of the permitting section as he is copied on the memorandum.

<u>ASBESTOS INSPECTOR</u>	<u>INSTITUTION</u>	<u>CERT. NO.</u>	<u>STATE</u>	<u>EXP. DATE</u>
Heath McGregor	Greenville Tech College	203-EVT502-093	SC	07/28/2021
		Included on the SRS Long-term in-house Group license ABS 8021		

<u>ASBESTOS INSPECTOR</u>	<u>INSTITUTION</u>	<u>CERT. NO.</u>	<u>STATE</u>	<u>EXP. DATE</u>
Mikell Autrey	Greenville Tech College	203-ETV502-089	SC	07/28/2021
		Included on the SRS Long-term in-house Group license ABS 8021		

C: C.R.F., 773-52A
Site D&D Correspondence File
J.K. Barrineau, 730-4B
Lance Cramer, 730-4B
William Griffin, 730-4B
John Blankenship, 730-4B