



January 9, 2020

Brian T. Hennessey
SRS Remedial Project Manager
Area Completion Project
U. S. Department of Energy
Savannah River Operations Office
P. O. Box A
Aiken, South Carolina 29802



RE: Facility Decommissioning Evaluation (FDE): Building 454-D, D-Area Diesel Fuel Tank, G-FDE-D-00041, Revision 0, November 13, 2019, Cover letter dated December 10, 2019

Dear Mr. Hennessey:

The South Carolina Department of Health and Environmental Control (SCDHEC) has reviewed the referenced document with respect to the Memorandum of Agreement for Achieving an Accelerated Cleanup Vision for the Savannah River Site (SRS). Please respond to the following comments.

General Comment

The integrity of the sumps for Diesel Fuel Tank and the Diesel Fuel Unloading Facility are not specifically addressed. Please address.


Specific Comments

Figure 7, Page 9 Please describe the significance of the blue rectangle which encompasses Building 454-D and Building 484-5D. The later facility is not covered in the FDE.

Part 2, Evaluation on page 15 Item 2 states, "There was no visible evidence of spills at the truck off-loading station." This statement is contradicted in the second paragraph on page 10. Please resolve this discrepancy.

If you have any questions, please contact Leigh Beatty at 803-642-1637 or via e-mail at beattykl@dhec.sc.gov.

Sincerely,



Gregory N. O'Quinn
SC Department of Health and Environmental Control
Midlands EA – Aiken

G-FDE-D-00041

cc: Travis Fuss, SCDHEC, Midlands EA
Susan Fulmer, SCDHEC, BLWM
Jon Richards, EPA Region IV
Chris Bergren, SRNS-ACP (signed original)