



ARF-024960

REGION 4
ATLANTA, GA 30303

ENVIRONMENTAL COMPLIANCE &

April 28, 2025

APR 28 2025

SRNS-OS-2025-00122

Mr. Matthew Baker, SRS Remedial Project Manager
Remediation and Deactivation & Decommissioning Division
U.S. Department of Energy
Savannah River Operations Office
P.O. Box A
Aiken, South Carolina 29802

AREA COMPLETION PROJECTS

**EPA Comments: FACILITY DECOMMISSIONING EVALUATION, BUILDING 720-F,
CENTRAL ALARM STATION, G-FDE-F-00062, REVISION 1 JAN 2025, SAVANNAH RIVER
SITE AIKEN, SOUTH CAROLINA**

Dear Mr. Baker,

The U.S. Environmental Protection Agency, Region 4 (EPA), has reviewed the Facility Decommissioning Evaluation for Building 730F Rev1. Our comment is below:

If you have any questions or require additional information, please contact me at (404) 431-1340.

Sincerely,

**JON
RICHARDS**

Digitally signed by JON
RICHARDS
Date: 2025.04.28 10:16:12
-04'00'

Jon Richards
FFA Remedial Project Manager
Superfund & Emergency Management
Division

cc: C.L. Bergren, SRNS-ACP
Susan Fulmer, SCDHEC

SPECIFIC COMMENT

1. **Process History, Page 11 of 14:** The text should discuss where the liquids that drained into the sump located in the diesel generator room were discharged. The text states that all building floor drains discharged to F-Area sanitary sewer system; however, whether the sump discharged to the sanitary sewer system is unclear. Also, the text should discuss why the sump currently contains water (e.g., the sump discharge line was grouted). *Please revise the text to discuss where the sump liquids were discharged to and if the discharge line has been grouted.*